

CEYEPETCO USD Consumer Account Process

Now Companies can apply for USD Priority Consumer facility

List of Basic Infrastructure Requirement for a Consumer Point

- ▶ Tank capacity should not be less than 2000LG (Imperial gallons)
- ▶ Tank should be fabricated out of steel and tank should possess a pressure test certificate.
- ▶ Tank should be properly installed, preferably underground
- ▶ If the tank is installed above the ground" power take off (PTO) pump should also be installed.
- ▶ inlet of the pump should be 2 1/2"
- ▶ Thread of the pump inlet should meet British Standard pipe Taper (BSPT)
- ▶ Fire extinguisher (Foam, Dry, and CO₂) should be available at the site
- ▶ Bowser can be reached up to tank location



0115 455 146 / 0115 455 248



CEYLON PETROLEUM CORPORATION



www.ceypetco.gov.lk